

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26932

1. OWNER Don H. & Joy M. Tibbals ADDRESS AT WELL LOCATION  
2 miles SE of Weed Heights  
 MAILING ADDRESS 2 Austin Drive  
Yerington, NV 89447 200' West of River

2. LOCATION NW 1/4 NE 1/4 Sec. 28 T. 13 N. R. 25 E. Lyon County  
 PERMIT NO. 57106 60702 61718 Weed Heights Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	17	17
Granite boulders		17	112	95
Boulders & cobbles in clay		112	123	11
Sand & cobbles		123	129	6
Boulders & cobbles in clay		129	153	24
Sand/gravel/cobbles		153	161	8
Boulders & cobbles w/some clay pockets		161	285	124
Clay		285	290	5
Sand & gravel		290	300	10
Boulders w/sand & gravel		300	320	20

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

From (Inches)	To (Inches)	From (Feet)	To (Feet)
48	0	0	20
30	0	0	100
22 1/2	100	100	320

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
42	16 ga	culvert	0	20
24	16 ga	culvert	0	100
14	36.7	.250	0	140

Perforations:  
 Type perforation Double row mill slot  
 Size perforation 1/8 .250 wall  
 From 140 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 0 feet to 300 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started July 2, 1994  
 Date completed July 8, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1200</u>	<u>125'</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address P.O. Box 590 Contractor  
Winnemucca, NV 89446  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-17-94