

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24235

1. OWNER Ron Lee ADDRESS AT WELL LOCATION 2832 East Valley Rd Gardnerville NV.
MAILING ADDRESS 2832 East Valley Rd Gardnerville NV. 89726
2. LOCATION SE 1/4 SE 1/4 Sec. 27 T 14 R 20 E Douglas County
PERMIT NO. 81-153-27 Parcel No. _____ Subdivision Name Johnson Lane

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Brown Sands</u>		<u>2</u>	<u>9</u>	<u>7</u>
<u>Brown Clays</u>		<u>9</u>	<u>23</u>	<u>14</u>
<u>Coarse Gravels</u>		<u>23</u>	<u>76</u>	<u>53</u>
<u>Brown Sandy Clays</u>		<u>76</u>	<u>115</u>	<u>39</u>
<u>Coarse Sands</u>		<u>115</u>	<u>124</u>	<u>9</u>
<u>Brown Clays</u>		<u>124</u>	<u>138</u>	<u>14</u>
<u>Coarse Sands</u>		<u>138</u>	<u>225</u>	<u>87</u>
<u>Solid Brown Clay</u>		<u>225</u>	<u>268</u>	<u>43</u>
<u>Broken/Sandy Gravels</u>	<u>XXX</u>	<u>268</u>	<u>320</u>	<u>52</u>

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)
From 10 1/4 Inches To 55 Feet
9 7/8 Inches 55 Feet 320 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.63</u>	<u>.188</u>	<u>0</u>	<u>320</u>

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 280 feet to 320 feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 55 Cement Grout
Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
From 55 feet to 320 feet

Date started 8-3 1994
Date completed 8-5 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>65</u>	<u>3 HRS</u>

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow _____ G.P.M. 25 P.S.I.
Water temperature 60.6 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO
5551 Hwy. 50 East
Gardnerville, Nevada
Address _____
Nevada contractor's license number 31839
issued by the State Contractor's Board
Nevada driller's license number issued by the 1905
Division of Water Resources, the on-site driller
Signed Michael L. Black
By driller performing actual drilling on site or contractor
Date 8-8-93