

OFFICE USE ONLY  
 Log No. 46558  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27015  
2195 Fullerson

1. OWNER DAVE HINZ ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 2073

2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 17 N/S R. 27 E. Churchill County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand	✓	0	31	31
Brown Clay		31	38	7
Brown Silt	✓	38	44	6
Brown Clay		44	56	12
DARK Silt		56	61	5
Sand & Gravel	✓	61	87	16

8. WELL CONSTRUCTION  
 Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>50</u>		
<u>6</u>	<u>50</u>	<u>87</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>87</u>

Perforations:  
 Type perforation Machine Slot  
 Size perforation .081

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 80 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 38-8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor  
 Address Box 888 Contractor  
Fallon

Nevada contractor's license number issued by the State Contractor's Board 4052  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date June 12-94

Date started June 8, 1994  
 Date completed June 8, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1</u>