WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46390
Permit No.
Basin 087

NOTICE OF INTENT NO. 8160

1. OWNER Boyles Bros. Drilling
MAILING ADDRESS 1707 S. 4490 W.
Salt lake City, Utah 84125

ADDRESS AT WELL LOCATION Boyles BRos
975 Industrial Way
Sparks, Nevada 89431

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 19 N/S R. 20 E Wahoe County
PERMIT NO. MO-605A (Issued by Water Resources) 34-401-02 (Parcel No.) Industrial Park (Subdivision Name) MW-7

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pulled well cap from ground cut PVC off two feet below ground fill holes with 1 bag cement 6 gals water, Covered 1' of hole with concrete the rest with dirt to retrun to natural state.				
Hole abandoned using neat cement. Hole ground by termmie pipe from the bottom up.				
Original depth of hole - 19 1/2'				
Static water level - 12'				
Casing not pulled, back filled and the top 2' cut off - variance granted.				
Hole poured with cement thru a tremmie pipe.				

'94 OCT 25 A11 11
STATE ENGINEER

Date started 10/14, 19.94.
Date completed 10/14, 19.94.

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 19½ Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 19½
Placement Method: ☐ Pumped ☒ Poured — termmie
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boyles Bros. Drilling Co. (Contractor)
Address 1707 S. 4490 W. (Contractor)
Salt Lake City, Utah 84125

Nevada contractor's license number issued by the State Contractor's Board 5380

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1883

Signed Mary K Hall
By driller performing actual drilling on site or contractor

Date 10-17-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627