

OFFICE USE ONLY  
Log No. 46619  
Permit No. 8-102  
Basin 8-102

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24688

1. OWNER Ron & Mary Hays ADDRESS AT WELL LOCATION 4310 Deedar ST.  
MAILING ADDRESS 4310 Deedar ST. Silver Springs Nr. 89429  
2. LOCATION S.E. 1/4 NE 1/4 Sec. 36 T 18 N/S R 24 E Lyon County Mountain View Sub # 4  
PERMIT NO. 18-513-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sandy top soil		0	5	5
Five to coarse sand		5	20	15
Brown clay		20	30	10
Gray clay		30	45	15
Brown clay + some coarse sand		45	70	25
Coarse Brown sand	X	70	140	70

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 140 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:  
Type perforation MILL  
Size perforation 1/8 X 3  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 50  Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 140 feet

Date started 11-28, 1994  
Date completed 11-29, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>0</u>	<u>2 Hrs.</u>

9. WATER LEVEL  
Static water level 65 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name ACE Drilling & Dev. Contractor  
Address P.O. Box 668 Contractor  
Silver Springs Nr. 89429  
Nevada contractor's license number issued by the State Contractor's Board 14299  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726  
Signed H.L. [Signature]  
By driller performing actual drilling on site or contractor  
Date 11-7-1994