

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Shelley Small ADDRESS AT WELL LOCATION 8 Falcon Way  
 MAILING ADDRESS P.O. Box 717 Yerington Nev 89447  
 2. LOCATION SE 1/4 SE 1/4 Sec. 4 T 13 S R 26 E LYON County  
 PERMIT NO. 14-621-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil-Clayish		0	8	8
Fine Sand		8	10	2
Clay-Fine Sand		10	20	10
Clay-Sand		20	23	3
Clay		23	30	7
Clay-Sand		30	39	9
Sand-Gravel		39	76	37
Clay-Brown		70	76	6
Coarse Sand		76	90	14
Brown Clay		90	93	3
Coarse Sand-Gravel		93	98	5
Clay-Coarse Sand		98	103	5
Coarse Sand-Gravel	X	103	115	12
Coarse Sand-Gravel-Rock	X	115	123	8

8. WELL CONSTRUCTION  
 Depth Drilled 123 Feet Depth Cased 124 6" Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 123 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.108</u>	<u>7.5</u>	<u>123</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 3/32 x 3" x 6 Rows  
 From 10.5 feet to 123 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 123 feet

Date started 1-13 1994  
 Date completed 1-18 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>20</u>	<u>5</u>	<u>1 1/2 HRS</u>

9. WATER LEVEL  
 Static water level 33 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N. ByBee Lane Contractor  
Yerington Nev 89447  
 Nevada contractor's license number 15646  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 634  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-20-94