

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27046
343 Hunter Parkway

1. OWNER Hammond Homes ADDRESS AT WELL LOCATION 343 Hunter Parkway
 MAILING ADDRESS 1730 Lottin Rd Fallon NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 19 N/S R. 29 E. Churchill County
 PERMIT NO. 08-343-14 Issued by Water Resources Parcel No. Ventura Acc Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	✓	0	20	20
Brown Clay		20	22	2
Grey Sand	✓	22	47	25
Grey Clay		47	67	20
Grey Sand	✓	67	87	20
Brown fine sand	✓	87	102	25

194 Oct 21 10:21 AM
 STATE OF NEVADA

8. WELL CONSTRUCTION
 Depth Drilled 102 Feet Depth Cased 102 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet To 50 Feet
 From 6 Inches 50 Feet To 102 Feet
 From _____ Inches _____ Feet To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>1</u>	<u>102</u>

Perforations:
 Type perforation Machine Slot
 Size perforation .070
 From _____ feet to _____ feet
 From 95 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 8-9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Contractor
 Address Box 888 Contractor
Fallon
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed W. J. Pfeiffer
 By driller performing actual drilling on site or contractor
 Date Oct 10-94

Date started Oct 6, 1994
 Date completed Oct 6, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>1</u>