WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46694
Permit No.
Basin 105

NOTICE OF INTENT NO. 22206

1. OWNER Rich Aikenhead
MAILING ADDRESS P.O. Box 369
Gard. NV 89410

ADDRESS AT WELL LOCATION 2807 E Valley RD
Minden, NV

2. LOCATION SE ¼ SE ¼ Sec. 27 T. 14 N/S R. 20 E Douglas County
PERMIT NO. Issued by Water Resources | 21-240-41 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand top soil		0	6	
Hard Pan sand		6	8	
Sand + clay		8	52	
Course Sand + clay - cobbles		52	161	
Gravel + Sand		161	170	
Sand gravel clay		170	195	
Sand + Silt		195	218	
Sand, gravel + clay		218	230	

'94 OCT -3 PM 4:45
STATE ENGINEER'S OFFICE

Date started 9/29, 1992
Date completed 10/2, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	+20 gpm	
No pump test		

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	230 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	20' perf	.188	210	230
6 5/8	Blank	.188	0	210

Perforations:
Type perforation Factory
Size perforation 3 x 5/32
From 210 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 230 feet

9. WATER LEVEL
Static water level 116 feet below land surface
Artesian flow NO G.P.M. +20 P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rawhack Drilling Inc. (Contractor)
Address P.O. Box 1359 (Contractor)
Minden, NV 89423
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1380
Signed Eddy Rawhack (By driller performing actual drilling on site or contractor)
Date 10/4/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627