X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 105

NOTICE OF INTENT NO. 27512

1. OWNER ADVENTURE CONSTRUCTION
MAILING ADDRESS RENO, NV
ADDRESS AT WELL LOCATION #6 DOUBLE SPRINGS GARDNERVILLE, NV

2. LOCATION SE ¼ SW ¼ Sec. 22 T. 11 N/S R. 21 E. DOUGLAS County
PERMIT NO. — Issued by Water Resources
35-240-06 Parcel No.
DOUBLE SPRINGS Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	54	54
SAND + GRAVEL		54	78	19
SANDY CLAY		78	90	12
SANDY CLAY w/GRAVEL		90	94	4
CLAY		94	97	3
SANDY CLAY		97	101	4
SAND		101	104	3
SAND + GRAVEL		104	116	12
SANDY CLAY w/GRAVEL		116	120	4
SAND + GRAVEL		120	128	8
SANDY CLAY w/GRAVEL		128	132	4
SAND + GRAVEL	✓	132	153	21
GRANITE		153	155	2

Date started 10-7, 1994
Date completed 10-14, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15+	—	3

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	155 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	155

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDCO EXPLORATION, INC. Contractor
Address 7780 CURRY RD. Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-14-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627