

OFFICE USE ONLY
 Log No. 46798
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14233

1. OWNER Carlton & Gayle MacCaslin ADDRESS AT WELL LOCATION 6160 Santavito St
 MAILING ADDRESS P.O. Box 4352
Pahrump, NV. 89041
 2. LOCATION NW 1/4 SW 1/4 Sec. 15 T. 21 N/S R. 54 E Nye County
 PERMIT NO. 45-131-31 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|-----|------------|
| Cobbles | | 0 | 38 | 38 |
| Clay | | 38 | 56 | 18 |
| Caliche | | 56 | 60 | 4 |
| Clay | | 60 | 73 | 13 |
| Caliche | | 73 | 79 | 5 |
| Clay | | 79 | 97 | 18 |
| Caliche | WB | 97 | 102 | 5 |
| Clay | | 102 | 120 | 22 |
| Caliche | WB | 120 | 124 | 4 |
| Clay | | 124 | 138 | 14 |
| Caliche | WB | 138 | 143 | 5 |
| Clay | | 143 | 167 | 24 |
| Caliche | WB | 167 | 172 | 5 |
| Clay | | 172 | 194 | 22 |
| Caliche | WB | 194 | 200 | 6 |
| Clay | | 200 | 225 | 25 |
| Caliche | WB | 225 | 230 | 5 |
| Clay | | 230 | 247 | 17 |
| Caliche | WB | 247 | 250 | 3 |

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8 7/8</u> | <u>16.94</u> | <u>.188</u> | <u>0</u> | <u>250</u> |

Perforations:
 Type perforation Factory Saw Cut
 Size perforation _____
 From 210 feet to 230 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 5.0
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump P, NV. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D.
 By driller performing actual drilling on site or contractor
 Date 11/17

RECEIVED
 NOV 29 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started October 30 1994
 Date completed November 1 1994

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|---|-------------------------------|--|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | G.P.M. | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |