WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46893
Permit No.
Basin

NOTICE OF INTENT NO. 14268

1. OWNER Avco Construction
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 4 Redrock

2. LOCATION NW ¼ NE ¼ Sec. 29 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 39-051-16 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Calichie		8	11	3
Clay		11	25	14
Calichie		25	28	3
Clay		28	45	17
Calichie		45	48	3
Clay		48	66	18
Calichie		66	68	2
Clay		68	75	7
Calichie	WB	75	79	4
Clay		79	93	14
Calichie	WB	93	95	2
Clay		95	113	18
Calichie	WB	113	115	2
Clay		115	125	10
Calichie	WB	125	130	5
Clay		130	136	6
Calichie	WB	136	140	4

RECEIVED DEC 27 1994 Div. of Water Resources Branch Office - Las Vegas, NV

Date started November 23, 19 94
Date completed November 26, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 12/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627