WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46928
Permit No.
Basin 162

NOTICE OF INTENT NO. 14323

1. OWNER Richard Erickson
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 6 Desert Hills Circle

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Desert Hills (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	6	3
Clay		6	8	2
Calichie		8	11	3
Clay		11	17	6
Calichie		17	20	3
Clay		20	26	6
Calichie		26	29	3
Clay		29	34	5
Calichie		34	37	3
Clay		37	47	10
Calichie		47	51	4
Clay		51	65	14
Calichie		65	70	5
Clay		70	78	8
Calichie	WB	78	81	3
Clay		81	96	15
Calichie	WB	96	110	14
Clay		110	123	13
Calichie	WB	123	125	2
Clay		125	137	12
Calichie	WB	137	140	3
Clay		140	152	12
Calichie	WB	152	159	7
Clay		159	166	7
Calichie		166	170	4
Clay		170	175	5

Date started December 27, 1994
Date completed December 29, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JAN 04 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	175

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.99	.188	0	175

Perforations:
Type perforation Factory Saw Cut
Size perforation
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 12/29/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627