WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46930
Permit No. 60087
Basin 163
NOTICE OF INTENT NO. 14376

1. OWNER Ed. Kolojay
MAILING ADDRESS
ADDRESS AT WELL LOCATION Quartz + Mohawk

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 25S N/S R. 57 E. Clark County
PERMIT NO. 60087 (Issued by Water Resources) 550-330-067 (Parcel No.) 219-06-501-017 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand.		0	12	12
Calichie		12.	14	2
Clay.		14	33	19
Calichie		33	35	2
Clay		35	42	7
Calichie		42	45	3
Clay.		45	57	12
Calichie.	WB	57	60	3
Clay.		60	65	5
Calichie	WB	65	67	2
Clay.		67	75	8
Calichie	WB	75	78	3
Clay		78	96	18
Calichie	WB	96	98.	2
Clay.		98	116	18
Calichie	WB	116	118	2
Clay		118	127	9
Calichie	WB	127	130	3
Clay		130	136	6.
Calichie.	WB.	136	139	3
Clay,		139	140	1

RECEIVED
JAN 04 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-21, 1994
Date completed 12-22, 1994

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.97	.188	-1	140

Perforations:
Type perforation SAW
Size perforation ⅛ inch by 3 inch
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 Ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 12-27-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627