

Log No. 47127

Permit No. _____

Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 544.340

NOTICE OF INTENT NO. 13238

1. OWNER MERLE B STEELE ADDRESS AT WELL LOCATION 8630 BELCASTRO
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 15 T 22 N/S R 60 E CLARK County
 PERMIT NO. 176-15-701-016 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + ROCKS.		0	5	5
CMT. GRAVEL.		5	70	65
CLAY		70	80	10
CMT. GRAVEL		80	110	30
LIMESTONE		110	115	5
CMT GRAVEL W/ STRKS CLAY		115	350	235
CMT. GRAVEL.		350	525	175
SANDSTONE	560	525	675	150
CMT. GRAVEL.		675	745	70

8. WELL CONSTRUCTION
 Depth Drilled 745 Feet Depth Cased 745 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 0 Feet 745 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+ 1</u>	<u>745</u>

Perforations:
 Type perforation FACTORY SAW
 Size perforation 18 x 2 1/2
 From 705 feet to 725 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 60

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 60 feet to 745 feet

RECEIVED
 MAR 14 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 510 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2-22, 1995
 Date completed 3-8, 1995

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WATER WELL SERVICES Contractor
 Address 6475 GARY AVE Contractor
LAS VEGAS, NV. 89139
 Nevada contractor's license number issued by the State Contractor's Board 022311
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1966
 Signed Timdall Coull
 By driller performing actual drilling on site or contractor
 Date 3-10-95

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	