

OFFICE USE ONLY
 Log No. 471461
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25953

1. OWNER Douglas County ADDRESS AT WELL LOCATION Douglas County Landfill
 MAILING ADDRESS Post Office Box 218 Gardnerville, Nevada
Minden, Nevada 89423

2. LOCATION SE 1/4 NW 1/4 Sec. 18 T. 12 N/S R. 21 E. Douglas County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
T.V. VIDEO OF WELL INDICATED WELL AT DEPTH WAS 280'. PERFORATIONS WERE FROM 252' TO 280' FOR ABANDONMENT PURPOSE WE PERFORATED CASING WITH MILLS KNIFE FROM 250' TO SURFACE EVERY 10' SLOT SIZE WAS 1/2" X 2. WE THEN PUMPED APPROX 6 CUBIC YARDS OF NEAT CEMENT FROM BOTTOM OF THE WELL UP TO THE SURFACE CASING WAS 8 5/8 X .188 WALL.				
MATT DILLON FROM DIVISION OF WATER RESOURCE WAS PRESENT FOR MOST OF THE ABANDONMENT.				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 280' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 250 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Irrigation Company Contractor
 Address 9955 North Virginia Street
Reno, Nevada 89506 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date November 9, 1994

Date started September 27, 1994
 Date completed September 28, 1994

7. WELL TEST DATA

TEST METHOD Bailer Pump Air-Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)