WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47172
Permit No.
Basin 162

NOTICE OF INTENT NO. 13171

1. OWNER Thomas Milton
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 25 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. APN 4256317 (Issued by Water Resources) | 8 Unit 2 (Parcel No.) | Calvada Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Grey Clay | | 4 | 20 | 16 |
| Brown Clay | | 20 | 46 | 26 |
| Soft Caliche | | 46 | 52 | 6 |
| Grey Clay | | 52 | 95 | 43 |
| Brown Clay | x | 95 | 148 | 53 |
| Hard Formation | | 148 | 153 | 5 |
| Brown Clay | | 153 | 160 | 7 |

RECEIVED
FEB 28 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started February 10, 1995
Date completed February 11, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | 0 Feet | 160 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | 18 lbs. | .188 | 0 | 160 |

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 89 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 Pahrump 89041 (Contractor)

Nevada contractor's license number 7484 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed (By driller performing actual drilling on site or contractor)
Date 2-15-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627