WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 47268
Permit No.
Basin 102

NOTICE OF INTENT NO. 26384

1. OWNER ROBIT JACKSON / GUARD, LTD.
MAILING ADDRESS P.O. BOX 7798 RENO, NV 89510
ADDRESS AT WELL LOCATION 5345 GREELEY AVE, SILVER SPRING, NV 89429

2. LOCATION NE ¼ NE ¼ Sec. 32 T. 18N N/S R. 24E E. LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 18-452-03 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, CLAY SMALL GRAVEL		0	300	300
GRAVELS FINE		300	360	60

Date started 1-23, 1995
Date completed 1-24, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT	45	N/A.	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	360

Perforations:
Type perforation MILLED SLOT
Size perforation 3/32 x 3"
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50' Per telcon w/ Driller
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 360 feet to 50' feet

9. WATER LEVEL
Static water level 240' feet below land surface
Artesian flow N/A. G.P.M. N/A. P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FREDRICK PUMP & SUPPLY (Contractor)
Address 2545 WESTVIEW BLVD (Contractor)
SPARKS, NV 89434
Nevada contractor's license number issued by the State Contractor's Board 036313
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974
Signed (By driller performing actual drilling on site or contractor)
Date 1-25-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627