

OFFICE 47396  
 Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin 089

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27304

1. OWNER DAVID & HENRIETTA CREPS ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 305 McClullinn Drive  
Carson City, NV 89704  
 2. LOCATION SW 1/4 NE 1/4 Sec. 32 T. 17N N/S R. 20 E. Washoe County  
 PERMIT NO. 050-398-04 New Washoe City Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hole have steel in bottom, pipe wrench jaw.				
Total depth 174 feet				
Yield app 4 GPM with air.				
WELL DEEPENING:				
Rusty weathered granite		174	195	21
Gray granite		195	202	7
Weathered granite		202	215	13
Soft zone (app 2 GPM)	X	215	216	1
Gray granite		216	248	32
Weathered gray granite with streaks of clay		248	282	34
Fracture (app 12 GPM)	X	282	283	1
Weathered granite		283	300	7
<i>Deepening of log to 158' 18"</i>				

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 174 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 175 feet to 185 feet  
 From 205 feet to 215 feet  
 From 275 feet to 295 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal deepening  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 170 feet to 300 feet

9. WATER LEVEL  
 Static water level 119 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 18 P.S.I.  
 Water temperature cold °F Quality clear

Date started 10-17-94, 19\_\_\_\_  
 Date completed 10-18-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 22549 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date October 21, 1994