WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

RECEIVED APR 11 1995

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47401
Permit No.
Basin

NOTICE OF INTENT NO. 14591

1. OWNER Edzoe Dunstee
MAILING ADDRESS Div. of Water Resources, Branch Office - Las Vegas, NV

ADDRESS AT WELL LOCATION 1580 Manse

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-071-31 (Parcel No.) Manko (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	13	9
Calichie		13	15	2
Clay		15	22	7
Calichie		22	24	2
Clay		24	41	17
Calichie		41	43	2
Clay		43	57	14
Calichie	WB	57	62	5
Clay		62	76	14
Calichie	WB	76	81	5
Clay		81	97	16
Calichie	WB	97	99	2
Clay		99	109	10
Calichie	WB	109	112	3
Clay		112	121	9
Calichie	WB	121	123	2
Clay		123	129	6
Calichie	WB	129	132	3
Clay		132	137	5
Calichie	WB	137	140	3

Date started March 17, 1995
Date completed March 20, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8" x 1 3/4"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor #
Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun
by driller performing actual drilling on site or contractor
Date 4/4/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627