WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 107

NOTICE OF INTENT NO. 25472

1. OWNER DOUBLE J.A. LAND & LIVESTOCK CO.
MAILING ADDRESS ARTIST VIEW & DAY LANE
SMITH, NV 89430

ADDRESS AT WELL LOCATION ARTIST VIEW & DAY LANE

2. LOCATION NE ¼ SE ¼ Sec. 7 T. 11 N/S R. 23 E. LYON County

PERMIT NO. 48739 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	55	
BRN CLAY		55	120	
SAND & COURSE SAND		120	163	
BLUE CLAY		163	225	
GRVLS W/SOME BRN CLAY	WB	225	280	
(PLUGGED BOTTOM OF				
WELL WITH DRAIN ROCK				
TO PREVENT SAND FROM				
COMING IN.)				

'94 NOV -7 P3:18
STATE ENGINEERS OFFICE

Date started 10 12, 1994
Date completed 10 12, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		5½

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		188	0	280

Perforations:
Type perforation 1/16 x 3 FACTORY
Size perforation 1/16 x 3
From 220 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ED MILLER (Contractor)
Address P.O. BOX 92 (Contractor)
SMITH, NV 89430

Nevada contractor's license number issued by the State Contractor's Board 32166

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1949

Signed [signature]
By driller performing actual drilling on site or contractor

Date 10 18 94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627