WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47437
Permit No.
Basin

NOTICE OF INTENT NO. 14792

1. OWNER Gustavo A. Villeda
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3300 W. Pueblo

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 20-S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-793-01 (Parcel No.) Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray clay		4	12	8
Brown clay		12	23	11
Gray clay		23	62	39
Brown clay/caliche	X	62	88	26
Brown clay		88	117	29
Brown clay/caliche	X	117	140	23

RECEIVED MAR 23 1995 Div. of Water Resources Branch Office - Las Vegas, NV

Date started March 9, 1995
Date completed March 9, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	½

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation 1/Torch Cut - 1/Factory Cut
Size perforation ¼"width 8"long - 1/8"width 3"long-
From 100 feet to 140 feet 8 rolls
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date March 10, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627