WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47454
Permit No.
Basin 230
NOTICE OF INTENT NO. 14564

1. OWNER VFW Post 6826
MAILING ADDRESS 59180 SE
ADDRESS AT WELL LOCATION White Sands St.

2. LOCATION ~~NW~~ ¼ SE ¼ Sec. 35 T. 16S N/S R. 49 E. N/YE County
PERMIT NO. 8 Issued by Water Resources | Parcel No. 14-631-42 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand, Dirt, Cobbles | | 0 | 4 | 4 |
| Clay - Cobbles | | 4 | 23 | 19 |
| Cemented - Gravel - Sand | | 23 | 51 | 28 |
| Calichie | | 51 | 68 | 17 |
| Sand - Gravel | | 68 | 91 | 23 |
| Sand - Gravel | WB | 91 | 117 | 26 |
| Calichie | | 117 | 120 | 3 |
| Sand - Gravel | WB | 120 | 130 | 10 |
| Calichie | | 130 | 135 | 5 |
| Sand - Gravel | WB | 135 | 145 | 10 |
| Calichie | | 145 | 150 | 5 |
| Sand - Gravel | WB | 150 | 158 | 8 |

Date started 2/20, 19 95
Date completed 2/24, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 158 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12¼ Inches | 0 Feet | 158 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 158 |
| | | | | |

Perforations:
Type perforation Factory Saw Cut
Size perforation 5/8 x 3
From 118 feet to 138 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 158 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Da
By driller performing actual drilling on site or contractor
Date 3/21/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627