WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47500
Permit No.
Basin 093

NOTICE OF INTENT NO. 22867

1. OWNER BOB MCCUTCHEN
MAILING ADDRESS 11515 Oregon Blvd.
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 1392 Antelope VAlley Road
Reno, Nevada 89506

2. LOCATION NW ¼ SE ¼ Sec. 23 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-470-28 (Parcel No.) Antelope Valley, Red Rock Estates #1 (Subdivision Name) part 4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	6	5
Brown clay with sand and gravel		6	31	25
Fine brown sand		31	35	4
Brown sandy clay, some smaller gravels with some boulders		35	81	46
Soft zone (FINE SAND)		81	88	7
Brown clay		88	111	23
Soft zone (MED SAND)	X	111	118	7
Brown clay		118	122	4
Soft granite sands	X	122	133	11
Brown sandy clay		133	135	2

Date started 1-2-95, 19
Date completed 1-3-95, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	135 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	135

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 135 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 5, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627