

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26428

1. OWNER Echo Bay Minerals ADDRESS AT WELL LOCATION M. Coy mine
MAILING ADDRESS P.O. Box 1658 Lander County
Battle Mt. NV. 89820
2. LOCATION NE 1/4 SE 1/4 Sec. 7 T. 28 N. R. 43 E. Lander County
PERMIT NO. MO-880
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>GRAVEL</u>		<u>0</u>	<u>190</u>	
<u>Limestone</u>		<u>190</u>	<u>300</u>	
	<u>X</u>	<u>190</u>	<u>210</u>	
	<u>X</u>	<u>160</u>	<u>167</u>	

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet
HOLE DIAMETER (BIT SIZE)
From 6 Inches To 0 Feet 300 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 inch</u>	<u>PVC</u>	<u>Sch 80</u>	<u>0</u>	<u>300</u>

Perforations:
Type perforation slotted
Size perforation .010
From Blank 0 feet to 240 feet
From Screen 240 feet to 280 feet
From Blank 280 feet to 300 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 15 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 300 feet to 180 feet

9. WATER LEVEL
Static water level 156 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 20.1 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLund Drilling Co Contractor
Address P.O. Box 2687 Contractor
EIKO NEVADA 89801
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller # 1759
Signed Tom Kouts
By driller performing actual drilling on site or contractor
Date Dec 16, 1994

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started Dec 14, 1994
Date completed Dec 16, 1994

95 JUN 30 P3 02
STATE ENGINEER