

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25584

1. OWNER BARRICK GOLDSTRIKE MINE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE  
 MAILING ADDRESS P.O. BOX 29  
ELKO, NEVADA 89801

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T 35 N 48 E EUREKA County  
 PERMIT NO. #VIC NEV. 93209 N/A Subdivision Name N/A  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MULTI COLORED ROCK		0	80	80'
MULTI COLORED ROCK & CLAY		80	215	135'
SOFT ROCK, SOME CLAY		215	855	640'
CLAY		855	980	125'
CLAY & BLACK ROCK		980	955	15'
HARD BLACK ROCK		995	1,015	20'
FRACTURED GRAY/BLACK ROCK		1,015	1,040	25'
HARD REDDISH BROWN ROCK		1,040	1,205	165'
REDDISH BROWN ROCK & CLAY		1,205	1,240	35'
FRACTURED REDDISH ROCK		1,240	1,320	80'
HARD REDDISH BROWN ROCK		1,320	1,460	140'
REDDISH BROWN ROCK LARGE		1,460		
FRACTURES			1,555	95'
HARD REDDISH BROWN ROCK		1,555	1,580	25'
REDDISH BROWN ROCK SMALL		1,580		
FRACTURES			1,660	80'
HARD REDDISH BROWN ROCK		1,660	1,695	35'
REDDISH BROWN ROCK, FRACTURED		1,695	1,710	15'
HARD REDDISH BROWN ROCK		1,710	1,785	75'
REDDISH BROWN ROCK SMALL		1,785		
FRACTURES			1,820	35'

8. WELL CONSTRUCTION  
 Depth Drilled 1820 Feet Depth Cased 1800 Feet

HOLE DIAMETER (BIT SIZE)  
 From 46 Inches To 0 Feet 37 Feet  
38 Inches 37 Feet 195 Feet  
24 Inches 195 Feet 1,820 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	142	.250	0	37
32	120	.250	0	195
24	95	.375	0	1,159'
24	95	.375	1,760	1,800'

Perforations: \_\_\_\_\_  
 Type perforation ROSCO MOSS FULL FLOW  
 Size perforation .125  
 From 1,159 feet to 1,760 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 1,035  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 1,035 feet to 1,820 feet

Date started SEPTEMBER 28, 19 94  
 Date completed OCTOBER 16, 19 94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 53' feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature 80 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UTAH 84104  
 Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1822  
 Signed ROD THOMPSON  
 By driller performing actual drilling on site or contractor  
 Date Rod Thompson