X

PPW-44

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47782
Permit No.
Basin 061

NOTICE OF INTENT NO.

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 36 (N)S R. 50 E. EUREKA County
PERMIT NO. 55150 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DISPLACED 75 SECOND FUNNEL				
VISCOSITY BENTONITE SLURRY				
FROM 700 FT TO 50 FT.				
DISPLACED 16 LB/GAL CEMENT				
SLURRY FROM 50 FT TO SURFACE.				

Date started DECEMBER 3, 19 94
Date completed DECEMBER 3, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18 ½ Inches	0 Feet	50 Feet
12 ¼ Inches	50 Feet	720 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	55	.375	0	50
6	17	.250	0	160
6	17	.250	180	260
6	17	.250	280	300

Perforations:
Type perforation MILL SLOT SCREEN
Size perforation
From 160 feet to 180 feet
From 260 feet to 280 feet
From 300 feet to 360 feet
From 380 feet to 600 feet
From 620 feet to 700 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 720 feet

9. WATER LEVEL
Static water level NONE feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1939

Signed KEVIN ELLISON Kevin Ellison
By driller performing actual drilling on site or contractor

Date 12/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627