NA-45

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47798 & 47799
Permit No.
Basin 062

NOTICE OF INTENT NO. 27946

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ SE ¼ Sec. 13 T 37 N/S R 48 E EUREKA County
PERMIT NO. M/O 795 (Issued by Water Resources) | N/A (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OXIDIZED VOLCANICS		0	1005	1005
VOLCANICS & CLAYS		1005	1165	160
OXIDIZED VOLCANICS		1165	1248	80
VOLCANICS		1248	1880	632
RED & GRAY CLAY & SANDSTONE		1880	2180	300

'94 NOV 15 A11:16
RECEIVED
STATE ENGINEER'S OFF

Date started OCTOBER 26, 1994
Date completed OCTOBER 31, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2,180 Feet Depth Cased 2,178 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-1/4 Inches	0 Feet	20 Feet
7-7/8 Inches	20 Feet	2180 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22	.250	0	20
1-1/4	3	SCH80	0	1098
1-1/4	3	SCH80	0	2078

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From 1098 feet to 1158 feet
From 2078 feet to 2178 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1,060 - 2,035 feet to 1,180 - 2,180 feet

9. WATER LEVEL
Static water level 786 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed Matt Waite (By driller performing actual drilling on site or contractor)
Date NOVEMBER 10, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627