




WHITE-DIVISION OF WATER RESOURCES  
 BUREAU-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. **47838**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **14447**

1. OWNER **WAYNE JACOBUS** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **PARRUMP NEV** **9114 ST LOT 22**  
**Block 7**

2. LOCATION **N 1/2 1/4** 1/4 Sec **28** T. **19.5** N/S R. **5.3** E. **NYE** County  
 PERMIT NO. \_\_\_\_\_ Parcel No. **29-902-22** Subdivision Name **BELL VISTA UNIT 3**

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
BRN CLAY		1	7	6
HARD BRN CLAY		7	13	6
GREY CALICHE		13	29	16
HARD BRN CLAY		29	41	12
HARD BRN CALICHE	WB	41	60	19
HARD BRN CLAY		60	72	12
BRN CLAY	WB	72	96	24
HARD BRN CLAY		96	111	15
BRN CLAY	WB	111	127	16
HARD BRN CLAY		127	160	33

8. WELL CONSTRUCTION  
 Depth Drilled **160** Feet Depth Cased **160** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**12 1/2** Inches **0** Feet **160** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8 5/8</b>	<b>17</b>	<b>1.88</b>	<b>0</b>	<b>160</b>

Perforations:  
 Type perforation **Torch cut**  
 Size perforation **1 1/4 x 6"**  
 From **110** feet to **160** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50'**  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From **50** feet to **160** feet

RECEIVED  
 JUN 06 1995  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level **60** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **Cold** °F Quality **Good**

Date started **MAY 20** 19**95**  
 Date completed **MAY 25** 19**95**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>25</b>	<b>1'</b>	<b>1 hr</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Ron Nailon Drilling** Contractor  
 Address **Box 265 Parrump NEV 89041** Contractor  
 Nevada contractor's license number issued by the State Contractor's Board **0035704**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1625**  
 Signed **Ron Nailon**  
 By driller performing actual drilling on site or contractor  
 Date **MAY 30 1995**