WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47845
Permit No. 60911
Basin 162

NOTICE OF INTENT NO. 14650

1. OWNER Tim Hafen
MAILING ADDRESS also permit # 60911
ADDRESS AT WELL LOCATION 5600 Bridger

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 21 N/S R. 54 E. Nye County
PERMIT NO. 61125 T (Issued by Water Resources) 43-052-01 (Parcel No.) Cottonwoods (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Calichie		5	7	2
Clay		7	19	12
Calichie		19	22	3
Clay		22	33	10
Calichie		33	35	2
Clay		35	46	11
Calichie		46	48	2
Clay		48	56	8
Calichie	WB	56	58	2
Clay		58	74	16
Calichie	WB	74	76	2
Clay		76	88	12
Calichie	WB	88	91	3
Clay		91	108	17
Calichie	WB	108	112	4
Clay		112	125	13
Calichie	WB	125	132	7
Clay		132	145	13
Calichie	WB	145	148	3
Clay		148	163	15
Calichie	WB	163	168	5
Clay		168	175	7

Date started May 10, 1995
Date completed May 15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JUN 13 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	175

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 6/5/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627