



WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 47998  
 Permit No. \_\_\_\_\_  
 Basin 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 16212

1. OWNER ADAM DAFFNER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec 19 T 23 N/S R. 60 E CLARK County \_\_\_\_\_  
 PERMIT NO. 176-19-701-002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY CLAY GRAVEL</u>		<u>0</u>	<u>200</u>	<u>200</u>
<u>W/STKS CMT GRAVEL</u>				
<u>CMT GRAVEL</u>		<u>200</u>	<u>340</u>	<u>140</u>
<u>CMT GRAVEL W/STKS OF RED SANDSTONE</u>	<u>510</u>	<u>340</u>	<u>590</u>	<u>250</u>
<u>RED SANDSTONE</u>		<u>590</u>	<u>620</u>	<u>30</u>
<u>CMT GRAVEL</u>		<u>620</u>	<u>700</u>	<u>80</u>

8. WELL CONSTRUCTION  
 Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 60 Feet  
9 7/8 Inches 60 Feet 700 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.188</u>	<u>+1</u>	<u>700</u>

Perforations:  
 Type perforation FACTORY SAW  
 Size perforation 1 1/2 X 2 1/2  
 From 640 feet to 680 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 60 feet to 700 feet

9. WATER LEVEL  
 Static water level 412 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8-14, 1995  
 Date completed 8-19, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE Contractor  
LAS VEGAS NV. 89131  
 Nevada contractor's license number issued by the State Contractor's Board 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594  
 Signed Pimdaew Couch  
 By driller performing actual drilling on site or contractor  
 Date 8-22-95

