WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48003
Permit No.
Basin

NOTICE OF INTENT NO. 17042

1. OWNER Phillip Jensen
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3111 W. Charleston

2. LOCATION NE ¼ NE ¼ Sec. 24 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-771-04 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	16	11
Calichie		16	19	3
Clay		19	28	9
Calichie		28	30	2
Clay		30	41	11
Calichie		41	43	2
Clay		43	52	9
Calichie	WB	52	54	2
Clay		54	69	15
Calichie	WB	69	73	4
Clay		73	88	15
Calichie	WB	88	91	3
Clay		91	103	12
Calichie	WB	103	105	2
Clay		105	114	9
Calichie	WB	114	117	3
Clay		117	128	11
Calichie	WB	128	131	3
Clay		131	136	5
Calichie	WB	136	140	4

DCNR/DWR Received AUG 25 1995 LAS VEGAS OFFICE

Date started August 14, 19 95
Date completed August 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 1/3
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr
By driller performing actual drilling on site or contractor
Date 8/23/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627