WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48012
Permit No.
Basin

NOTICE OF INTENT NO. 17027

1. OWNER Thomas Snively
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5921 South Hafen Road,

2. LOCATION SW ¼ SW ¼ Sec. 10 T. 21S N/S R. 54 E. Nye County
PERMIT NO. Issued by Water Resources | 45-121-17 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Dirt Cobbles		0	7	7
Clay + Cobbles		7	34	27
Cemented Sand + Gravel		34	67	33
Sandy Clay		67	72	5
Caliche		72	75	3
Clay		75	84	9
Caliche		84	87	3
Clay		87	96	9
Caliche	WB	96	103	7
Clay		103	117	14
Caliche	WB	117	122	5
Clay		122	131	9
Caliche	WB	131	134	3
Clay		134	146	12
Limestone	WB	146	151	5
Clay		151	154	3
Caliche	WB	154	159	5
Clay		159	168	9
Caliche	WB	168	171	3
Clay		171	175	4

DCNR/DWR Received AUG 25 1995 LAS VEGAS OFFICE

Date started 7-21, 1975
Date completed 7-26, 1975

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.57	.188	+1	175

Perforations:
Type perforation SAW
Size perforation ⅛ inch by 3 inch
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on site or contractor
Date 8-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627