

Log No. 48015
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT-NO. 26584

1. OWNER GARY WILSON ADDRESS AT WELL LOCATION 793 RUBIO GARDNERVILLE
 MAILING ADDRESS 812 SHORT CT GARDNERVILLE NV

2. LOCATION SW 1/4 SE 1/4 Sec. 20 T. 12 N. R. 20 E DOUGLAS County
 PERMIT NO. 27-703-01 MARRON ESTATES Subdivision Name

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles, gravel & sand</u>		<u>0</u>	<u>38</u>	<u>38</u>
<u>gravel w/ sandy clay</u>		<u>38</u>	<u>43</u>	<u>5</u>
<u>gravel</u>		<u>43</u>	<u>50</u>	<u>7</u>
<u>gravel w/ sandy clay</u>		<u>50</u>	<u>54</u>	<u>4</u>
<u>gravel</u>		<u>54</u>	<u>81</u>	<u>27</u>
<u>gravel w/ sandy clay</u>		<u>81</u>	<u>86</u>	<u>5</u>
<u>gravel w/ short sandy clay</u>		<u>86</u>	<u>140</u>	<u>54</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>100</u> Feet	
<u>9 3/8</u> Inches	<u>100</u> Feet	<u>140</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>12</u>	<u>140</u>

Perforations:
 Type perforation Factory slotted
 Size perforation 3x3/32

From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed James R. Plimel By driller performing actual drilling on site or contractor
 Date 5-4-95

Date started 5-1 1995
 Date completed 5-4 1995

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>	<u>—</u>	<u>3</u>

95 MAY -8 P12:34
 STATE ENGINEERS OFF