



WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 48023  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

NOTICE OF INTENT NO. 17012

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Jon King ADDRESS AT WELL LOCATION 7920 Quarterhorse  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T. 21 S. N/S R. 54 E Uye County  
 PERMIT NO. 45-244-04 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	2	2
Caliche		2	4	2
Clay		4	14	10
Caliche		14	17	3
Clay		17	25	8
Caliche		25	27	2
Clay		27	44	17
Caliche		44	47	3
Clay		47	52	5
Caliche	WB	52	59	7
Clay		59	60	1
Caliche	WB	60	63	3
Clay		63	71	8
Caliche	WB	71	74	3
Clay		74	83	9
Caliche	WB	83	85	2
Clay		85	100	15
Caliche	WB	100	103	3
Clay		103	113	10
Caliche	WB	113	115	2
Clay		115	123	8
Caliche	WB	123	126	3
Clay		126	136	10
Caliche	WB	136	140	4

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 2" x 3"

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
 Address HCR 78 Box 80358  
Pahrump, NV. 89041  
 Nevada contractor's license number 80880  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas  
 By driller performing actual drilling on site or contractor  
 Date 8/8/85

Date started July 12 1985  
 Date completed July 17 1985

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

