WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48033
Permit No.
Basin 090

NOTICE OF INTENT NO. 26955

1. OWNER Deeter Trust
MAILING ADDRESS 774 Mays Blvd
Incline Village, NV 89451

ADDRESS AT WELL LOCATION 1820 Hwy 50
S. Tahoe, NV

2. LOCATION SW ¼ NE ¼ Sec. 15 T. 14 N/S R. 18 E/W Douglas County

PERMIT NO. | Issued by Water Resources | 01-110-12 Parcel No. | None Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Granodiorite		0	109	109
Silty Broken	X	109	175	66
Fracs or Broken	X	175	220	45
V Hard		220	280	60
Broken, Fracs, Caving	X	280	340	60
Solid From 345-375		340	375	

'95 MAY 10 A10:45
STATE ENGINEER

Date started 9/20, 1994
Date completed 10/3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35/45		4 Hrs

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	100 Feet
8 Inches		100 Feet	375 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		1/4	+2	100
6 5/8	13	.188	+2	375

Perforations:
Type perforation Sawcut - Double
Size perforation 3 X 3/32
From 190 feet to 210 feet
From 230 feet to 250 feet
From 270 feet to 290 feet
From 310 feet to 330 feet
From 350 feet to 370 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 375 feet

9. WATER LEVEL
Static water level ? feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reich (Driller performing actual drilling on site or contractor)
Date 10/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627