WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48034
Permit No.
Basin 162

NOTICE OF INTENT NO. 17033

1. OWNER Robert Cornet
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1800 S. Redrock

2. LOCATION SE ¼ SE ¼ Sec. 20 T. 20S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 39-042-03 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	6	3
Clay		6	14	8
Calichie		14	17	3
Clay		17	23	6
Calichie		23	25	2
Clay		25	39	14
Calichie		39	42	3
Clay		42	57	13
Calichie		57	61	4
Clay		61	69	8
Calichie	WB	69	73	4
Clay		73	83	10
Calichie	WB	83	85	2
Clay		85	99	14
Calichie	WB	99	102	3
Clay		102	111	9
Calichie	WB	111	113	2
Clay		113	118	5
Calichie	WB	118	127	9
Clay		127	135	8
Calichie	WB	135	140	5

DCNR/DWR Received AUG 14 1995 LAS VEGAS OFFICE

Date started July 31, 19 95
Date completed August 2, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 8/8/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627