

Log No. 48087
 Permit No. _____
 Basin. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27259

Consultant: OWNER Boder Cont.
 MAILING ADDRESS 1254 St. Alberts ADDRESS AT WELL LOCATION 1545 Del Monte Ln
Reno, Nevada 89503 Reno, Nevada 89511
 2. LOCATION SE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 36 T. 19N N/S R. 19E E. Washoe County
 PERMIT NO. 040-152-1517 (A) SW Reno Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Black Clay some Gravels		2	19	17
Brown Sandy Clay		19	38	19
Yellow Sandy Some gravels with Clay		38	49	11
Brown Clay		49	81	32
Dark Brown Cklay with smaller Boulders.		81	104	23
Soft Zone Med. Sand	X	104	111	7
Brown Sandy Clay		111	139	28
Soft Zone	X	139	140	1
Sandy Brown Clay some smaller Gravel.		140	144	4
Brown Clay		144	150	6
soft Zone	X	150	160	10
Brown Clay		160	163	3
Soft Zone	X	163	170	7
Brown Clay		170	187	17
Soft Zone	X	187	197	10
Brown clay		197	202	5

8. WELL CONSTRUCTION
 Depth Drilled 202 Feet Depth Cased 202 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet 202 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	202

 Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 3/32 x 3 x 5 around
 From 202 feet to 182 feet
 From 162 feet to 142 feet
 From 122 feet to 102 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 _____ Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 202 feet

Date started 4-27-95 19_____
 Date completed 5-4-95 19_____
 STATE ENGINEERS OF NEVADA

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow _____ G.P.M. 40+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature] driller performing actual drilling on site or contractor
 Date May 4, 1995