

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27057

1. OWNER Dinedend Const ADDRESS AT WELL LOCATION Sky's River Edge
MAILING ADDRESS _____

2. LOCATION SW 1/4 NW 1/4 Sec 29 T 19 N/S R 28 E Churchill County
PERMIT NO. _____ Issued by Water Resources Parcel No. 8-551-40 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	12	12
Brown Clay		12	16	4
Brown silt	-	16	31	15
Black silt	-	31	68	37
Grey Clay		68	74	6
Brownish yellow silt		74	88	14
Black clay		88	96	8
Black silt	-	96	109	13
Grey silt	-	109	139	30
Brown silt	-	139	160	21

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>			<u>50</u>	
<u>6</u>			<u>160</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>160</u>

Perforations:
Type perforation Machine Slot
Size perforation 7/8 - 0.020

From _____ feet to _____ feet
From 154 feet to 158 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 9 - 4' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started Sept 30, 1994
Date completed Sept 30, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor
Address Box 888 Fallon Nevada Contractor
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed Welsco By driller performing actual drilling on site or contractor
Date Sept 30 - 94