WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48154
Permit No.
Basin 049

NOTICE OF INTENT NO29126

1. OWNER Rod Torres
MAILING ADDRESS 2151 Pinion Rd #184
Elko, NV 89803

ADDRESS AT WELL LOCATION North side of south 3rd, 400' East of Comanche

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 35 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) 35-029-06 (Parcel No.) MVR #3 (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Clay		0	45	45
Brown Sandy Siltstone		45	110	65
Sand & Med Gravel	X	110	118	8
Brown-Yellow Clay		118	134	16
Green-Brown Siltstone		134	150	16
Sand & Gravel	X	150	180	30

'95 APR 20 AM 9:48
STATE ENGINEER

Date started 4-3, 19 95
Date completed 4-4, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	180

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627