WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48220
Permit No.
Basin 8-1/01

NOTICE OF INTENT NO. 32988

1. OWNER Michael Casey
MAILING ADDRESS 1550 Allen RD
Fallon NV 89406

ADDRESS AT WELL LOCATION
14310 Carson Hwy
Fallon NV 89406

2. LOCATION NE ¼ NW-SE ¼ Sec. 25 27 T. 19 N/S R. 26 E. Churchill County
PERMIT NO. (Issued by Water Resources) | 007-071-53 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Silt		5	18	13
Brown Clay		18	33	15
Sand		33	60	27
Clay		60	72	12
Sand		72	78	6
Brown Clay		78	98	20
Sand		98	122	24
Clay		122	130	8
Sand		130	150	20
Clay		150	160	10
Sand		160	175	15

Date started June 17, 1995
Date completed June 17, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	175 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	155	175

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling INC. (Contractor)
Address P.O.box 1265 (Contractor)
Fallon NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/7/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627