



WHITE—DIVISION OF WATER RESOURCES
 PRIMARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 48280
 Permit No. 42405
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14032

1. OWNER LILLIAN JACOBSON ADDRESS AT WELL LOCATION 4904 BRONCO
L.V. NV.
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T 19 N/S R 60 E CLARK County
 PERMIT NO. 42405 Parcel No. 125-35-802-005 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY + CALICHE		0	80	80
LIMESTONE		80	90	10
CLAY	175	90	190	100
CLAY + CALICHE		190	350	160
* OLD WELL HAD SHEAR @ APPROX 170' BACKFILLED W/ WASHED PEA GRAVEL TO 145' AND CEMENTED FROM 145' TO SURFACE.				

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
14 3/4 Inches 0 Feet 55 Feet
12 1/4 Inches 55 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>350</u>
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>55</u>

Perforations:
 Type perforation FACTORY SAW
 Size perforation 18 x 2 1/2
 From 310 feet to 330 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 350 feet

9. WATER LEVEL
 Static water level 158 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started _____, 19____
 Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WATER WELL SERVICES Contractor
 Address 6475 GARY AVE Contractor
LAS VEGAS, NV. 89139
 Nevada contractor's license number 022311
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1966
 Division of Water Resources, the on-site driller
 Signed Timothy Couch
 By driller performing actual drilling on site or contractor
 Date 7-13-95

