WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48284
Permit No.
Basin 163

NOTICE OF INTENT NO. 14680

1. OWNER EDWARD & ELSIE KOLOJAY
MAILING ADDRESS 9124 SUNDIAL Dr.
LAS VEGAS, NV. 89134

ADDRESS AT WELL LOCATION TETON + DOLOMITE
SANDY VALLEY NV.

2. LOCATION SE¼/NE¼ NW¼/NW¼ Sec. 22 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-160-125 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
CALICHIE		8	12	4
CLAY		12	25	13
CMT. SAND & GRAVEL		25	30	5
CLAY & GRAVEL		30	58	28
CMT. SAND & GRAVEL		58	69	11
CLAY & GRAVEL		69	78	9
CALICHIE		78	87	9
CMT. SAND & GRAVEL		87	120	33
CALICHIE	W.B	120	125	5
CLAY		125	133	8
CALICHIE	W.B	133	139	6
CLAY		139	159	20
CALICHIE	W.B	159	164	5
CLAY		164	174	10
CALICHIE	W.B	174	178	4
CLAY		178	180	2

DCNR/DWR Received JUL 13 1995 LAS VEGAS OFFICE

Date started 6-19, 19 95
Date completed 6-21, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	180

Perforations:
Type perforation FACTORY SAWCUT
Size perforation 8 INCH BY .3 INCH
From 180 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 180 feet to 50 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. (Contractor)
Address P.O BOX 3505 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-21-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627