

Log No. 48511
 Permit No. 087
 Basin 087
 NOTICE OF INTENT NO. 32851

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SCOLARS WAREHOUSE ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 255 So. McCarran Bl. Sparks, Nev.
 2. LOCATION N/W 1/4 N/E 1/4 Sec. 9 T. 19 N/S R. 20 E. WASHOE County
 PERMIT NO. n/a 909 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other HAMMER

6. LITHOLOGIC LOG NW 1

Material	Water Strata	From	To	Thickness
<u>LIGHT COBBLES</u>		<u>0</u>	<u>15'</u>	<u>15'</u>
<u>SANDS W/ GRAVELS</u>		<u>15'</u>	<u>30'</u>	<u>15'</u>
<u>COARSE SAND - W/ SOME SILTY SANDS</u>		<u>30'</u>	<u>40'</u>	<u>10'</u>

8. WELL CONSTRUCTION
 Depth Drilled 40' Feet Depth Cased 40' Feet
 HOLE DIAMETER (BIT SIZE)
 From 6" To 40'
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>sch 40</u>	<u>PK</u>	<u>0</u>	<u>40'</u>

Perforations:
 Type perforation FAC .020
 Size perforation
 From 30' feet to 40' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 16' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 40' feet to 16' feet

9. WATER LEVEL
 Static water level 30' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Dilling Contractor
 Address 1635 BELFORD RD. RENO NV. 89509 Contractor
 Nevada contractor's license number 34525 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Andrew Dilling by driller performing actual drilling on site or contractor
 Date 4/21/95

Date started 3-17, 1995
 Date completed 3-17, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

'95 MAY -5 AM 10
 RECEIVED
 STATE ENGINEERS OFFICE