MW-95-3

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 48569
Permit No.
Basin 137B

NOTICE OF INTENT NO. 25436

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nv. 89045

ADDRESS AT WELL LOCATION
RMGC Minesite

2. LOCATION SE ¼ SE ¼ Sec. 24 T. 10 N/S R. 43 E. Nye County

PERMIT NO. M/O 901 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite wash-Boulders		0	770	
Brn Clay-Volcanics		770	868	
Hard Red Glassie Rock		868	870	
Lake sediments Tuff		870	880	

Plugged by Well Log 112569

Date started March 17, 1995
Date completed March 22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		4 hrs.

8. WELL CONSTRUCTION
Depth Drilled 890 Feet Depth Cased 890 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
8 3/4 Inches	50 Feet	890 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.81	.188	+1	880

Perforations:
Type perforation Slotted
Size perforation 1/8 X 3" 64 slot P/ft.
From 240 feet to 260 feet
From 520 feet to 540 feet
From 560 feet to 580 feet
From 604 feet to 620 feet
From 640 feet to 660 feet
680 700

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured Bentonite Chips 50'-240'
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 240 feet to 890 feet

9. WATER LEVEL
Static water level 442 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co. (Contractor)
Address 2220 Stone Dr (Contractor)
Reno, Nv. 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Woytek (By driller performing actual drilling on site or contractor)
Date 3-24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627