

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 48617  
 Permit No. 57458  
 Basin. 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17099

1. OWNER Gary Vigoren ADDRESS AT WELL LOCATION 5600 Hwy 160  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NW 1/4 Sec 15 T. 19S N/S R. 53 E Nye County  
 PERMIT NO. 57458 Issued by Water Resources Parcel No. 29-232-05 Subdivision Name COUNTRY PLACE II

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	40	40
Clay SAND		40	90	50
Cemented Gravel		90	120	30
Gravel	WB	120	140	20
Sandy clay		140	163	23
Gravel	WB	163	190	17
SANDY clay		180	190	10

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:  
 Type perforation Factory Saw cut  
 Size perforation 1 1/8 x 3  
 From 150 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

9. WATER LEVEL  
 Static water level: 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9-28, 1995  
 Date completed 9-29, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump NV 89041

Nevada contractor's license number issued by the State Contractor's Board: 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1642

Signed Thomas Du  
 By driller performing actual drilling on site or contractor  
 Date 10/4/95

