

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17034

1. OWNER George Stanford ADDRESS AT WELL LOCATION 3270 W. Shawnee Ave.
 MAILING ADDRESS Steven Balint

2. LOCATION NW 1/4 NW 1/4 Sec. 35 T. 20 S N/S R. 53 E County Clark
 PERMIT NO. 42-691-09 Parcel No. _____ Subdivision Name Calvada Valley

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Caliche		3	5	2
Clay		5	12	7
Caliche		12	17	5
Clay		17	37	20
Caliche		37	41	4
Clay		41	53	12
Caliche	WB	53	55	2
Clay		55	64	9
Caliche	WB	64	67	3
Clay		67	76	9
Caliche	WB	76	78	2
Clay		78	94	16
Caliche	WB	94	96	2
Clay		96	103	7
Caliche	WB	103	107	4
Clay		107	116	9
Caliche	WB	116	118	2
Clay		118	125	7
Caliche	WB	125	129	4
Clay		129	136	7
Caliche	WB	136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches _____ Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 3/8" x 3"

From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level: 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started July 26 1995
 Date completed July 28 1995

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 9-29-145

