

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 4881
Permit No. _____
Basin 078

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27934

1. OWNER Winnemucca Farms ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P O Box 130 1 mile west of Winnemucca
Winnemucca, NV 89446

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 1 T. 35 N/S R. 37 E Humboldt County
PERMIT NO. MO-923 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Silty Clay		5	30	25
Sand & Gravel		30	32	2
Clay		32	55	23
Sand & Gravel		55	65	10
Clay		65	70	5
Sand & Clay		70	85	15
Letter attached on materials & construction	<u>Stainless Centralizers top & bottom</u>			

'95 MAY 16 AIO 51
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 85 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 88 Feet
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	PVC	Sch. 80	+1	50
2 1/2	PVC	Sch. 80	80	85

Perforations:
Type perforation Sch. 80 PVC Screen
Size perforation .020
From 50 feet to 80 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured
Gravel Packed: Yes No CKIZ wash
From 50 feet to 85 feet

9. WATER LEVEL
Static water level: 58 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature NORM °F Quality good

Date started April 22, 1995
Date completed April 23, 1995

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
<u>Til clear</u>	<u>1</u>		<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co Inc Contractor
Address P O Box 590 Contractor
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board: 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1713
Signed C. C. Apple
By driller performing actual drilling on site or contractor
Date 5-10-95