WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48800
Permit No.
Basin 207

NOTICE OF INTENT NO. 22965

1. OWNER Ernest H Gubler Inc.
MAILING ADDRESS PO Box 152 Lund NV 89317
ADDRESS AT WELL LOCATION Lots 11 & 12 Block 3

2. LOCATION SW ¼ NW ¼ Sec. 33 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 13-141-03 (Parcel No.) Lund 5 acre plat (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
Clay		3	9	
gravel		9	10	
Clay		10	20	
gravel		20	21	water
Clay		21	26	
gravel		26	47	water
Clay		47	53	
gravel		53	60	water
Clay		60	66	
gravel		66	67	water
Clay		67	77	
gravel		77	78	water
Clay		78	82	
Lime Stone		82	83	
Clay		83	88	
gravel		88	90	
Clay		90	92	

'95 APR 27 A11:17
STATE ENGINEER'S OFFICE

Date started March 20, 1995
Date completed April 11, 1995

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	17	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 92 Feet Depth Cased 92 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	53 Feet
6 Inches	53 Feet	92 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.9	.189	-18	92

Perforations:
Type perforation mill
Size perforation ⅛ x 2.5 x 6 row
From feet to feet
From feet to feet
From 54 feet to 92 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 13.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Nathan R Maynard (Contractor)
Address PO Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date April 12 -95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627