WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48889
Permit No.
Basin 049

NOTICE OF INTENT NO. 29915

1. OWNER Bill A CRANE
MAILING ADDRESS 19 W Hannam Blvd MI 98602
ADDRESS AT WELL LOCATION Lot 9-D North side of Summit Dr

2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 34 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) Lot 9-D (Parcel No.) Elko Summit Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sodsoil		0	1	1
White SANDSTONE		1	100	99
Lose SANDSTONE	X	100	109	10
White SANDSTONE		109	154	45
Lose SANDSTONE	X	154	163	9
Green CLAY mix		163	210	47
with shale				

Date started 4-3, 1995
Date completed 4-16, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	NU	2.5

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16 Inches	0 Feet	210 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+15"	210'

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 90 feet to 110 feet
From 190 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 210 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fearing Drilling co (Contractor)
Address PO Box 525 (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627