

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26591

1. OWNER GENDA CEMETERY ASSOCIATION ADDRESS AT WELL LOCATION CEMETERY RD. GENDA
MAILING ADDRESS P.O. Box 70 GENDA, NV 89411

2. LOCATION NE 1/4 NE 1/4 Sec. 9 T. 13 N. R. 19 E. DOUGLAS County
PERMIT NO. 58775 17-072-13 GENDA Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders - DG w/ sandy clay		0	90	90
Sandy clay w/ gravel		90	101	11
Boulders w/ sandy clay		101	110	9
Sandy clay w/ gravel		110	159	49
Boulders w/ sandy clay	✓	159	178	19
Sandy clay w/ gravel		178	225	
gravel w/ sandy clay	✓	225	260	
Boulders w/ sandy clay		260	280	
gravel w/ sandy clay	✓	280	320	
Sandy clay w/ gravel		320	370	
Boulders w/ sandy clay	✓	370	400	

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
9 1/2 Inches 50 Feet 400 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>400</u>

Perforations:
Type perforation Factory Slotted / T.C.
Size perforation 3 x 3/32

From T.C. 160 feet to 180 feet
From Factory 220 feet to 240 feet
From T.C. 240 feet to 280 feet
From Factory 280 feet to 320 feet
From T.C. 320 feet to 340 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 143 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
Address 7780 CURRY RD. FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed [Signature] by driller performing actual drilling on site or contractor
Date 4-28-95

Date started 4-10, 1995
Date completed 4-28, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>	<u>-</u>	<u>3</u>

'95 MAY -8 P12:34
STATE ENGINEER (K)